

**SPREAD FOOTING SECTION**

Place concrete in toe, against undisturbed material, except as permitted by the Engineer.

**DESIGN SECTION****ELEVATION****TABLE OF REINFORCING STEEL, DIMENSIONS AND DATA**

DESIGN H		4'	6'	8'	10'	12'
W		4'-9"	5'-9"	6'-6"	7'-6"	8'-6"
C		1'-5"	2'-0"	2'-0"	2'-4"	2'-6"
B		3'-4"	3'-9"	4'-6"	5'-2"	6'-0"
⊗ BARS		#5 @ 16	#5 @ 16	#5 @ 8	#6 @ 8	#8 @ 8
⊗ BARS		#5 @ 16	#5 @ 16	#6 @ 16	#5 @ 8	#6 @ 8
LOAD CASE I	Ser: B', q <sub>0</sub>	4.4, 0.7	5.2, 0.9	5.5, 1.2	6.2, 1.4	7.0, 1.6
	Str: B', q <sub>0</sub>	4.4, 1.5	5.0, 1.7	5.2, 2.1	5.9, 2.4	6.6, 2.7
LOAD CASE II	Ser: B', q <sub>0</sub>	4.8, 0.5	5.8, 0.7	6.2, 1.0	7.0, 1.3	7.7, 1.7
	Str: B', q <sub>0</sub>	4.7, 1.0	5.7, 1.3	6.1, 1.8	6.8, 2.2	7.5, 2.7

Dist	COUNTY	ROUTE	POST MILES	SHEET TOTAL
			TOTAL PROJECT	No. SHEETS
May 20, 2011				
PLANS APPROVAL DATE				
THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF SCANNED COPIES OF THIS PLAN SHEET.				

**DESIGN CONDITIONS:**

Design H may be exceeded by 6" before going to the next size. Special footing design is required where foundation material is incapable of supporting bearing stress listed in table.

**DESIGN NOTES:**

DESIGN: AASHTO LRFD Bridge Design Specifications, 4th edition with California Amendments

LIVE LOAD: Surcharge on level ground surface

SOIL:  $\phi = 34^\circ$   
 $\gamma = 120 \text{ pcf}$

REINFORCED CONCRETE:  $f_y = 60,000 \text{ psi}$   
 $f'_c = 3,600 \text{ psi}$   
 $n = 8$

**NOTES:**

- For details not shown and drainage notes see (B3-5)
- For wall stem joint details see (B0-3) and (B0-3)
- At @ and Short @ bars:  
H  $\leq$  6', no splices are allowed within 1'-8" above the top of footing.  
H > 6', no splices are allowed within H/4 above the top of footing.

**SYMBOLS:**

Ser - service limit state 1  
Str - strength limit state 1  
B' - effective footing width (ft)  
q<sub>0</sub> - net bearing stress (ksf)  
q<sub>0</sub> - gross uniform bearing stress (ksf)

STATE OF CALIFORNIA  
DEPARTMENT OF TRANSPORTATION

**RETAINING WALL  
TYPE 1A**

NO SCALE

**B3-3**